



कार्यालय अधिकासी अभियन्ता (मु०)  
जलकल विभाग-नगर निगम प्रयागराज  
पत्र सं० ७८ मु०ज०क०वि०  
दिनांक २२.०७.२०२५

## JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-07/10

Date: 22.07.2025

### DRINKING WATER ANALYSIS REPORT

1	Name & Address	S.R MEMORIAL SCHOOL, GADDOPUR PHAPHAMAU, PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	Drinking Water(R.O)
4	Date of Sample Collection	18.07.2025
5	Date of Sample Receiving	18.07.2025
6	Date of Analysis Completed	22.07.2025

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	26.8	-	-
4.	Turbidity	NTU	0.6	5	10
5.	Conductivity at 25°C	µmho/cm	59.0	-	-
<b>CHEMICAL PARAMETERS</b>					
6.	pH	-	6.7	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	Nil	-	-
8.	Dissolved Solids	mg/L	24.0	500	2000
9.	Total Solids	mg/L	24.0	-	-
10.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	39.2	200	600
11.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	18.4	200	600
12.	Chlorides (as Cl)	mg/L	15.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	NIL	1.0	1.5
14.	Nitrate (as NO <sub>3</sub> )	mg/L	NIL	45.0	100.0
15.	Iron (Fe)	mg/L	NIL	0.3	1.0
<b>BACTERIOLOGICAL PARAMETERS</b>					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

\*Note: The water is suitable for drinking purposes-

Analyst

Manager

S. R. Memorial School  
Phaphamau, Allahabad

JE(HQ)

अधिकासी अभियन्ता (मु०)  
जलकल विभाग  
नगर निगम प्रयागराज

- Note:
1. The above results are related only to the test performed on the sample.
  2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
  3. Sample will be destroyed in the after fifteen days from the date of reporting.

## ANNEXURE C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 70

Dated: 09-07-25


It is certified that an inspection team headed by SR E.S. Shivam Mishra  
(Name of Officers with designation) from Jal Kail Vibhag Nagar Nigam Prayagraj PHED  
inspected the S.R. Memorial school, Gaddopur, Phaphamau, Prayagraj (U.P)

(Name & Address of the school) on 10/07/25 (date of inspection) and on the  
basis of Water Test Report (Attached) bearing no. 78 (PHED Lab) dated  
09.07.25

(Name of school) has safe drinking water facilities for the students and members of staff of the  
institution. School is also maintains the hygienic sanitation condition in the school building & the  
campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Three month only.

Signature with Seal:

  
जलकल विभाग  
नगर निगम-प्रयागराज

Name: E.S. Shivam Mishra

Designation: EE (HQ)


To

The Principal

S.R. Memorial School

Gaddopur, Phaphamau, Prayagraj -211013

Note: The certificate is to be issued by authorized officer/ PHED Lab / local bodies.

  
Manager  
S. R. Memorial School  
Phaphamau, Allahabad

  
S. R. Memorial School  
(Affiliated to CBSE)  
Phaphamau, Prayagraj-211013  
School Code-71562